

## ADDENDUM COVER SHEET

### Addendum No. 3

Chew Playground Field Renovations RFP (1800 Washington Ave.)

Philadelphia Redevelopment Authority

Issue Date: March 17, 2022

---

#### ITEM:

1. In Addendum 1, the response to Question 13 says that two allowances were added to the price sheet with assumed quantities. The revised price sheet did not have these allowances. Please provide along with assumed quantities.  
**The allowances have been removed as there are unit prices for same line items that have been added. The quantities may vary with the takeoffs.**
2. Detail 2 on Sheet C-401 calls for 2" of sand above and below the Smartdrain belts but does not say how wide. Does the sand go across the entire field or is it just confined to a certain width around the Smartdrain belt?  
**Sand should be an even layer below the entire field.**
3. There is a line on the pricing sheet for "Excavation of Soil" and a separate line for "Excavation of *Contaminated* Soil." If all of the soil is contaminated, what is the reason for the line that says "Excavation of Soil?" Are we to assume some of the soil is not contaminated? If so, what quantity?  
**They are one and the same. Ignore the duplicate.**