

## Martin Luther King Jr. Drive Street Light Replacement: Questions/RFIs:

1. Would you be able to supply us with the Lighting specifications for the fixtures required to replace?
  - Street lighting would like the GE Evolve LED Roadway Series ERL2023C340ADKBZL 133 for this project.
  - Please use the lighting fixtures for roadway and backside lighting.
    - ERLH015C340ADKBZL for any backside lighting
    - ERL2023C340ADKBZL (R23C4) for main lighting
2. Does the City of Philadelphia Questionnaire & Financial Statement need to be submitted prior to the bid opening? Or is it to be submitted with our bid submission on the day of the bid?
  - Please submit with your Bid
3. Is a bid processing fee required with our bid submission? Or is the bid processing fee waived for this project?
  - There is no bid processing fee for this project